

## Detail of pool backwash discharge pit in non-sewered areas

- The minimum dimensions have been calculated on 200 litres of water used during a backwash session. Should the system you have chosen use a larger volume of water, the volume of the pit should be increased in proportion.
- May connect to existing roof water rubble pit via existing drain as indicated below (alternate connection).
- Pool backwash must be contained within the property and should not be discharged over the ground or onto the garden.
- Any features of a swimming pool must be 6m or greater away from on-site disposal areas.

