

200 series masonry block wall refer MBRC standard drawing SL-1040 for wall details. Alternatively provide reinforced concrete wall refer suitably qualified RPEQ for wall and footing design	
Exterior joints to be filled tight with suitable compressed grout to manufacturers specification Waterproofing membrane on	
fill side of wall	
Adjoining surface as per design drawings	
e (as required) accordance with rawing RS-140	
<u>NG WALL / SEAT SECTION</u>	
be dense un-cracked, un-weathered rock approved by	y

- Clean stone using fresh water spray jet, prior to laying.
- Provide full depth control joints through stone and supporting wall at
- Waterproofing membrane to be in accordance with AS4654.

E WALLS	Moreton Bo Regional Council	y
	DRG No. SL-1050	
	original size A3	REVISION